

DEDICATED FREIGHT CORRIDOR CORPORATION OF INDIA LIMITED

(A Government of India Enterprise)

**Reply to queries for
SYSTEM WORKS CONTRACT PACKAGE**

NCB No.: HQ/SYS/DB/NKWD-DGO

S. No.	Part	Section	Volume	Pg. No.	Clause	Relevant Abstract from Tender	Query / Clarification	Reply to queries
255	2	V(B)	9	109	Attachment 13.1 Rev 1	Addendum 2	In the SLD shown in Addendum 2, outgoing feeder for staff quarter, Service Building from MDB are shown. Please clarify whether these buildings are there in Karwandiya, Kudra & Durgawati stations. If yes, please provide the drawings for the same as it is required for calculating the transformer load & other equipments sizing.	Please refer reply to query no. 10.
256					Addendum 2	Station Building drawing	Please confirm whether the station building drawing provided in Addendum 2 is same for all the three stations i.e. Karwandiya, Kudra & Durgawati or it is different for Kudra station as Kudra is a crossing station and other two are junction stations.	Yes.
257						There is no comment on other transmission lines coming on the way of proposed 132KV lines from BSEB to DFCC TSS. Please convey the suitable path without any infringement or advice any transmission line, if exists on the way as per your survey.	We are not satisfied by the reply provided by the DFCC at Sl. No. 14. If there is any unavoidable situation and we will have to cross the 132KV transmission line, then what will be the role of DFCC?	It will be the responsibility of System contractor. DFCCIL shall facilitate. Please refer Annexure-1, Utilities of Volume 6, Section V(A), Part 2.

258	2	V(B)	9	46	8.8.5		It is assumed that path for BEC shall be provided by Civil contractor only. Please confirm. The employers reply to first set of queries doesn't clarify the above query.	Please refer para 8.8.5.2 of Volume 9, Section V(B), Part 2.
259	2	V(B)	9	52	8.17.1	All Insulators shall be suitable for use in tropical environment. In polluted and vandalism prone areas silicone insulators conforming to RDSO Specification No. TI/SPC/OHE/INSCOM/1070(01/07) shall be provided and all other places only porcelain insulator conforming to RDSO Specification No. TI/SPC/OHE/INS/0070(04/07) shall be provided	It is requested that clear quantity shall be specified in terms of length of polluted section and non-polluted section for better clarity.	Please refer para 8.17.2 of Volume 9, Section V(B), Part 2.
260	2	V(A)	6	129-134	Appendix 15	Enginners Accommodation	Whether the land for engineer accommodation/office will be provided by the employer	Please refer reply to query no. 30. Also refer para 4.9 of Volume 1, Part 2
261	2	V(B)	9	59	10	Test train and traction power for trial run	Whether the cost of test train and traction power for the trial run will be borne by the employer	Yes.