

**ADDENDUM -I**  
**Reply to Pre-Bid Queries**

**Tender No.:** DFCCIL/NOIDA UNIT / Electrical/ Substation /2021/01  
**Name of Work:** Supply, Erection, Testing and Commissioning of 33 kV Sub-stations, DG Set and related works for DFCCIL Integrated Office Cum Residential Complex at Sec-145, Noida.

<u>S.No</u>	<u>Queries Raised By Bidders</u>	<u>Reply By DFCCIL</u>
1	Acceptance of "Bid Security Declaration" in lieu of "Bid Security/EMD" as per Ministry of Finance, Office memorandum No. F.9/4/2020-PPD dated 12/11/2020.	Provision of submission of "Bid Security Declaration" in place of " EMD" is being done.
2	Acceptance of EMD in the form of Bank Guarantee in lieu of Online Payment	Provision of submission of "Bid Security Declaration" in place of " EMD" is being done.
3	Change of Payment Terms from existing pattern of 1. 60% payment against Supply of Major Equipment. 2. 40% payment against Installation, Testing, Commissioning of Major Equipment.	Payment Terms are being revised as below :- 1. 70% payment against Supply of Major items. 2. 15% payment against Installation of Major items. 85% payment on supply and installation of other items. 3. 15% payment against Testing, Commissioning and handing over of all items.
4	Provision of 10% Mobilisation Advance against Bank Guarantee.	Not Acceptable.
5	Amendment in Make list to include following makes for below items :- <ul style="list-style-type: none"> <li>• HT Panel :- CGL, Adlec, Sudhir, Advance Panel, RP Control, Systems and Controls All authorised channel partners of OEM.</li> <li>• LT Panel :- All authorised channel partners of OEM.</li> <li>• APFC Panel :- Advance.</li> <li>• LT Equipment :- L&amp;T, Legrand.</li> <li>• Transformer :- CGL.</li> <li>• Busducts :- C&amp;S, Godrej, EAE, Advance-Anant Power.</li> <li>• DG Sets :- Perkins, Greaves, Kirloaskar.</li> <li>• 33kV Equipment :- Approved Make of PVVNL, Voltamp, Sudhir.</li> <li>• 33kV VCB :- OEMs of Schneider, ABB, Siemens.</li> <li>• 33kV XLPE Cables :- Gloster, Polycab.</li> <li>• LT Cables :- Gloster, Polycab.</li> <li>• External Lighting :- Crompton, Havells.</li> </ul>	Makes of some items are being revised.
6	Consideration of "S.I.T.C of HT Power Line ( 33kV and above ) or 11kV/ 433V substation works" in definition of "Similar works" for Technical Eligibility Criteria.	Not Acceptable.

*B. Kumar*  
*Apurva*

7	Consideration of "Completion of a part or component of ongoing work, even if overall scope of work is incomplete" for the Technical Eligibility Criteria.	Not Acceptable.
8	Consideration of providing "Enhancement to value of executed works already completed at a yearly rate" for Technical Eligibility Criteria.	Not Acceptable.
9	Price variation in case delay of project due to DFCCIL/Civil Works.	Not Acceptable.
10	Requirement of Character Certificate issued by DM in the State of UP or SDM in state of Delhi.	Not Required.
11	Requirement of Class "A" approved Electrical Contractor License.	The Tenderer shall have a valid electrical contractor's license issued in the name of firm by State Govt. for carrying out the tendered work. (to be enclosed along with the offer)
12	Period of Completion as 12 months instead of 9 months	Not Acceptable.
13	Scope of provision of Ms support, Chequered plate & RCC Cover in Masonry Trenches.	It is not in the scope of this tender.
14	Revision of Prices of Scheduled Items based on CPWD E&M 2018, Considering price escalation to year 2021.	Not required.
15	Revision of Prices for Cable laying of size 400 sq mm.	Not required.
16	Discrepancy of price in subhead "Total of External Lighting" .	Item rate of BOQ item 11.2 is being rectified. Total BOQ price of External Lighting remains same.
17	Modification of Technical Specification of Busducts & 33kV Cables.	Being Modified.

B. Kumar  
APM/27/11  
27/11  
APM/Elect/Noida

GM/Elect/Noida

27/11/2021