



# डेडीकेटेड फ्रेट कोरीडोर कॉर्पोरेशन ऑफ इण्डिया लिमिटेड

(भारत सरकार का उपक्रम)

मानस नगर, रेलवे कालोनी, पं. दीन दयाल उपाध्याय नगर (मुगलसराय), चन्दौली- 232101(यू पी)  
Mobile: +917897412000, Email: cpmmgs@gmail.com/ ajitmishra@dfcc.co.in

## Amendment No.1 Dated 10.06.2020

**Tender Notice No.** MGS/EN/DDU/RUB-FOB/296/2020 dated 11.05.2020


**Name of Work:** Construction of 01 No. RUB in lieu of LC No. 112 along with the approach portion and 03 no. FOBs falling in the DDU yard of DDU division of East Central railway in connection with construction of Eastern Dedicated Freight Corridor.

**Tenderers are notified about following changes in the Tender Document of above captioned tender:**

S. No.	Ref. in Original Tender Document	Existing provision	Revised provision
	Part / Chapter / Clause / Para No.		
1	Financial Bid, Packet -B, Schedule-B-VI, Item S.No.-18	Providing and fixing permanently colour coated trapezoidal profiled sheet of depth 28-30mm at 195-205mm pitch distance with precisely engineered "Rib & Flute" design. Profiled sheets shall be min. 0.5mm TCT/0.45mm BMT high tensile zinc aluminium alloy coated zincalume / galvalume steel sheet (550 mpa yield strength) having a coating of mass of 150 gsm zinc-aluminium coating AZ150 total on both sides as per AS 1397:1993 finished with 20 microns approved colour coating of Silicon Modified Polyester (SMP) / Super Polyester paint coat on exposed surface over a primer coat of 5 microns and a back coat of 5 microns on reverse side over a 5 microns primer coat. There shall be 2 small ribs/square flutes between profiles for providing additional strength. The sheet to be fixed over the purlins with hexagonal head self drilling suitable fasteners with neoprene / EPDM washer on crests of the sheet	Providing & fixing machine made UV stabilised fiberglass reinforced plastic sheet roofing upto any pitch including fixing with polymer coated 'J' or 'L' hooks, bolts and nuts 8mm dia. G.I. plain/bitumen washers complete but excluding the cost of purlins, rafters, trusses etc. The sheets shall be manufactured out of 2400 TEX panel rovigs incorporating minimum 0.3% Ultra-violet stabilizer in resin system under approximately 2400 psi and hot cured. They shall be of uniform pigmentation and thickness without air pockets and shall conform to IS 12866. The sheets shall be opaque or translucent, clear or pigmented, textured or smooth as specified.  a. 2mm thick corrugated and profile sheets

All other Terms & Conditions in the original Tenderer remains same. Tenderers are advise to visit websites [www.dfccil.com](http://www.dfccil.com) and [www.tenderwizard.com/dfccil](http://www.tenderwizard.com/dfccil) for details.

Yours Sincerely,

  
10/06/2020  
(Ajit Kumar Mishra)  
General Manager/Co  
DFCCIL/DDU